CITY OF FERNHOLLOW - DEPARTMENT OF PUBLIC WORKS

ADDENDUM NO. 1

Date of Issue: February 27, 2026

Bid No. PW-2026-031 - Maple Avenue Water Main Replacement

This Addendum forms a part of the Bid Documents and modifies the original Bid Documents dated February 9, 2026. Bidders shall acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

CHANGES TO THE BID DOCUMENTS

1. Bid Schedule, Item 4: The estimated quantity of 6-inch Gate Valve and Box is revised from 4 to 6. A revised Bid Form is attached and replaces the original Bid Form.
2. Specification Section 33 11 00, Paragraph 2.3: Pipe joints shall be push-on type with restrained joints at all fittings.

QUESTIONS AND ANSWERS

Question: Will night work be permitted on Maple Avenue between Third Street and Fifth Street?

Answer: No. Work hours are limited to 7:00 a.m. through 6:00 p.m., Monday through Friday.

All other terms and conditions of the Bid Documents remain unchanged.